

**DANCERT****DANISH TECHNOLOGICAL  
INSTITUTE**Dancert A/S  
Gregersensvej 1  
DK-2630 Taastrup  
Phone +45 72202160  
info@dancert.dk  
www.dancert.dk  
CVR no. DK-29512094

# Verifikationsattest

## DAN-24-BEK99-1977 rev.00

EU-notified body No. 1073

### Bilag til verifikationsattest DAN-24-BEK99-1977 rev.00

**Beskrivelse af udstyr / Equipment information:**

Beskrivelse <i>Description</i>	Ombygning af injektionsstation – Rør Solrød Biogas
Serie nr. <i>Serial no.</i>	1905 2333
Tegningsnr. / rev. <i>Drawing no. / rev.</i>	1905 1001 (rev 02) / 1905 1002 (rev 03)
Fremstillingsår <i>Year of manufacture</i>	2024

Design information	Inlet	Outlet	[unit]
Max. tryk (PS) <i>Max. pressure (PS)</i>	7	7	Bar
Min./Max. temperatur (TS) <i>Min./Max. temperature (TS)</i>	-20/50	-20/50	°C
Nominal Diameter (DN) <i>Volume (DN)</i>	80	100	DN
Fluida gruppe <i>Fluid Group</i>	I	I	I / II
Prøvningstryk (PT) <i>Test pressure (PT)</i>	26	26	Bar

Design / Review	Vurdering / Evaluation
Konstruktion, Materialer, designdata	I overensstemmelse
Beregninger og styrkemæssige vurderinger	I overensstemmelse
Endelige sammenføjninger (WPS/WPQR)	I overensstemmelse

**Revisioner af verifikationsattest**

Project No.	Beskrivelse / Description	Revision No.	INT.	Date
236438	Første godkendelse	00	JARA	08-03-2024

The appendix is not publicly available on [www.dancert.com](http://www.dancert.com)