



Certifikat 7137

Bilag 1 – 16-04-2024

Indbrudshæmmende produkter iht. EN 1627:2021 Dørsæt, vinduer, curtain walling, gitre og skodder - Indbrudssikring - Krav og klassifikation

Omfatter produkterne:

Roller shutter - "Rullejalousi Type 74 - 4 meter". (massive with no visual look through)
tested size: 4009 x 2500 mm (W x H)

Classifikationsrapport: Teknologisk Institut 873593-T-r1 Rullejalousi 74 – RC3 – Group 3 product.

Dimensions	Minimum	Testet	Maximum	Classification
Width/Bredde	-50%	4009 mm	+20%	RC3 - Group 3
Clear opening height/højde	-50%	2500 mm	+20%	

Fixed steel grille with hooks and fixed eyes in sides. (c-c 110 x 110 mm grid with 10 mm bars) Dimension: 3000 x 1495 mm (w x h)

Classifikationsrapport: Teknologisk Institut 947495 - RC3 – Group 4 product

Dimensions	Minimum	Testet	Maximum	Classification
Width/Bredde	No limit	3000 mm	3000 mm	RC3 - Group 4
Clear opening height/højde	No limit	1495 mm	1495 mm	

* Expert statement required if need for larger then tested.

leveret af

JSA - Sikring ApS

Elsted byvej 18
DK-8520 Lystrup